## **Exercise session 4**

Internal Stability of LFT. Structured Singular Value  $\mu$ . Structured Robust Stability and Performance.  $\mu$  Synthesis via D-K iterations.

## **Reading Assignment**

Read [Zhou] Ch. 10. Optional reading:

## **Exercises**

- **E4.1** [Zhou] 10.1
- **E4.2** [Zhou] 10.4
- **E4.3** [Zhou] 10.9
- **E4.4** Consider a system *P* and a controller *K*

$$P(s) = \frac{1}{75s+1} \begin{pmatrix} -87.8 & 1.4 \\ -108.2 & -1.4 \end{pmatrix}, \quad K(s) = \frac{75s+1}{s} \begin{pmatrix} -0.0015 & 0 \\ 0 & -0.075 \end{pmatrix}$$

and a diagonal uncertainty  $\Delta = \text{diag}\{\delta_1, \delta_2\}$ .

- (a) With the help of Robust Toolbox calculate  $\mu_{\Delta}(T)$  (= min<sub>D</sub>  $||DTD^{-1}||$ . Why?) and ||T|| at the frequency  $\omega_0 = 0.2$  for  $T = KP(I + KP)^{-1}$ . Estimate the conservatism.
- (b) Analyze  $T(j\omega_0)$  and  $D_{\min}T(j\omega_0)D_{\min}^{-1}$  and indicate the property that you think most contributes to this difference.
- (c) Assume the multiplicative uncertainty model

$$P_{\Delta} = P(I + W\Delta), \quad W(s) = \frac{s + 0.2}{0.5s + 1}, \ \|\Delta\|_{\infty} < 1$$

and the performance criterion to be

$$\|W_p(I+P_{\Delta}K)^{-1}\|_{\infty} \leq 1, \quad W_p(s) = \frac{s+0.1}{2s}.$$

- 1. Test stability robustness ignoring the structure of  $\Delta$ .
- **2.** Test stability robustness taking into account the structure of  $\Delta$ .
- 3. Test nominal performance.
- **4.** Test robust performance taking into account the structure of  $\Delta$ .

## Hand-In problems:

**H4.1** [Zhou] 10.3

**H4.2** Consider a stable nominal plant *P* and an uncertainty model

$$P_{\Delta} = (I + W_1 \Delta_1) P + W_2 \Delta_2, \quad \|\Delta_i\|_{\infty} < 1.$$

The robust performance objective is to achieve

$$||W_3(I+P_{\Delta}K)^{-1}||_{\infty} \leq 1$$

for all  $P_{\Delta}$ .

- (a) Make a block diagram for the closed loop system showing all weights and uncertain blocks.
- (b) Pull out all uncertainties and redraw the block diagram as upper LFT for uncertainties and lower LFT for K with respect to a generalized plant G. Determine the generalized plant G.
- (c) Close G by K and find the resulting closed loop function M (in terms of LFT).
- (d) Giva a condition for stability robustness, ignoring the structure of  $\Delta$ .
- (e) Giva a condition for stability robustness, taking into account the structure of  $\Delta$ .
- (f) Repeat last item for robust performance.
- (g) Under condition that the plant is SISO find the analytical expressions for robust stability and robust performance.